

Demo Door Co.

345 West Industrial Road

Anytown, USA 58466

p:(555) 555-5555 | f:(555) 444-4444

service@demodoorco.com

**Door - Configuration**

Report Date Apr 16, 2015 13:33 MDT

This report summarizes and describes the current configuration of the door system.

Customer:	Westek Building Products, Inc.	Building:	Truss Plant
Address	45870 - 62 Avenue, Pleasantville, AB, CA - T8K 5L3		
Contact 1:	Harry Cumberland	Contact 2:	Patricia Anderson
Phone:	555-555-5555	Phone:	555-555-5564
Email:	harry.cumberland@westek.com	Email:	patricia.anderson@westeck.com

Door ID & Description
Door ID 0001317
Description PUR 20' x 14' E/O

PM Schedule

Jan	Feb	Mar
Apr	May	Jun
Jul	Aug	Sep
Oct	Nov	Dec

Door Notes	532, North door
------------	-----------------

BUILDING & ENVIRONMENT

Cycles per Day	26-50 cycles/day
Environment	Normal

OPERATOR

Mode of Operation	Electric operator
Type	Hoist/Jackshaft - belt
Manufacturer	Manaras-Opera
Operator Detail	3/4 hp, 115 volt - 1 phase
Model	MSJ
Control Board Type	070M (Monitored)
Wall Stn / Secondary Controls	3-function O/C/S, No secondary controls
Control Programming	Not constant pressure-to-close
Timer-to-Close	Not enabled
Primary Entrapment Device	Monitored photo-eyes
Secondary Entrap. Device(s)	None
Accessories	Spreader bar, Protective cover

DOOR

Sectional Door Type	Polyurethane insulated
Manufacturer	Garaga
Model	G-5000
Door Size	Width(20'), Height(14')
Lift Configuration	Standard lift
Track Hardware	3", Bracket, Pusher springs
Jambs / Trusses	Steel jambs, Steel trusses
Cables	5/32"
Glazing & Windows	Individual windows
Glazing Detail - Individual	7, Glass - double pane
Accessories	No safety devices, No accessories
Door Type	Sectional